

Certificate



No.: 968/FSP 1375.01/18

Product tested Level Transmitter **Certificate holder** Hawk Measurement Systems Pty. Ltd.
15-17 Maurice Crt.
Nunawading, Victoria 3131
Australia

Type designation Centurion Guided Radar
CGR2L

Codes and standards IEC 61508 Parts 1-7:2010 IEC 61326-3-1:2017

Intended application The level transmitter complies with the requirements of the relevant standards (Hardware Safety Integrity SIL 2 according to IEC 61508 and Systematic Capability SC 3) and can be used in applications up to SIL 2 (HFT=0) resp. SIL 3 (HFT=1) for the safety functions MIN, MAX or monitoring of a range.
The product was also reviewed for the use in the application area of IEC 61511-1 up to SIL 2 (HFT=0) / SIL 3 (HFT=1).

Specific requirements The instructions of the associated Operating Manual and Safety Manual shall be considered.

Valid until 2023-03-28

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1375.01/18 dated 2018-03-28.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2018-03-28

Certification Body Safety & Security for Automation & Grid

Dr. R. G. A.
Dr.-Ing. Thorsten Gantevoort