



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx BKI 08 0016 issue No.: 0 Certificate history:

Status: **Current**

Date of Issue: **2008-10-31** Page 1 of 3

Applicant: **Magnetrol International N.V.**
Heikensstraat 6
B-9240 Zele
Belgium
Belgium

Electrical Apparatus: **Digital Level transmitter system type E3 Modulelevel**
Optional accessory:

Type of Protection: **General requirements, Intrinsically safe**

Marking: **Ex ia IIC T4 Ga**
-40°C up to +70°C

Approved for issue on behalf of the IECEx
Certification Body:

Janos HANKO

Position:

Director

Signature:
(for printed version)

Date:

2008-10-31

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

Testing Station for Explosion Proof Equipment
H 1037 BUDAPEST
MIKOVINY S.u. 2-4
Hungary



Ex



IECEx Certificate of Conformity

Certificate No.: IECEx BKI 08.0016

Date of Issue: 2008-10-31

Issue No.: 0

Page 2 of 3

Manufacturer: **Magnetrol International Inc.**
5300 Belmont Road
Downers Grove, IL 60515
U.S.A.
United States of America

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex product covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identification documents, was found to comply with the following standards:

IEC 60079-0 : 2004 Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
Edition: 4.0

IEC 60079-11 : 1999 Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'
Edition: 4

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[HU/BKI/ExTR08.0015/00](#)

Quality Assessment Report:

[CA/CSA/QAR06.0004/01](#)



IECEx Certificate of Conformity

Certificate No.: IECEx BKI 08.0016

Date of Issue: 2008-10-31

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

STANDARDS: IEC 60079-0:2007 Electrical apparatus for explosive atmosphere – Edition: 5 Part 0: General requirements
IEC 60079-11:2006 Electrical apparatus for explosive atmosphere – Edition: 4 Part 11: Intrinsically safe "i"
IEC 60079-26:2006 Electrical apparatus for explosive atmosphere – Edition: 2 Part 26: Equipment with equipment protection level (EPL) Ga
IEC 60079-27:2008 Electrical apparatus for explosive atmosphere – Edition: 2 Part 27: Fieldbu intrinsically safe concept (FISCO)

CONDITIONS OF CERTIFICATION: NO

Annexe: [Addendum to IECEx BKI 08.0016.pdf](#)



1. Description

Digital level transmitter type E3 Modulelevel

2. Type assortment

E3 X - X X X X - X X X

Legend of the signs from left to right

- 1_ , 2_ Code for manufacturer
- 3_ Code mounting and material
- 4_ , 5_ , 6_ , 7_ Type specifications
- 8_ Output (Hart, Fieldbus, Profibus)
- 9_ Integral / Remote temperature range
- 10_ Housing material / approval / cable entry
A = Aluminium, Ex i, I² NPT
B = Aluminium, Ex i, M20
C = SST, Ex i, I² xNPT
D = SST, Ex i, M20

3. Electrical parameters

3.1 4-20 mA models (HART)

- U_i = 28.4 V
- I_i = 94 mA
- P_i = 0.67 W
- C_i = 2.2 nF
- L_i = 3µH

3.1 FISCO models

- U_i = 17.5 V
- I_i = 380 mA
- P_i = 5.32 W
- C_i = 0.706 nF
- L_i = 3µH

4. Ambient temperature

-40°C up to +70°C

5. Ingress protection

The transmitter enclosure provides a degree of protection IP66 as per IEC 60529.

Special conditions for safe use:

Materials marked as using in "Zone 0 equipment" shall be installed in such a way that, even in the event of rare incidents, the aluminium enclosure cannot be an ignition source due to impact or friction.

Drawings

Report No. 0.07127		30 pages		2008.04.29
The installation and operating manual E3 Modulelevel				
099-7219	Modulelevel III	2 pages	rev A	2007.05.14
094-5056	Wiring board	3 pages	rev E	2007.11
030-9151	Safety wiring board	2 pages	rev H	2007.11
009-9346-001		2 pages	rev A	2008.01.29
094-6052	Enhanced 705 Digital Board Schematic	3 pages	rev E	2007.08.20
030-9145	Enhanced 705 Digital Board Assembly	3 pages	rev V	2007.08.17
09-9310-001		6 pages	rev G	2008.04.24
094-6053	Enhanced M16C H1&PA Fieldbus Digital Board	4 pages	rev K	2007.08
030-9150	M16C Fieldbus Digital Board Assembly	3 pages	rev R	2007.08
09-9323-001		6 pages	rev G	2008.04.24
094-6060	Schematic Modulelevel III Analog Board	2 pages		2007.12.12
030-2475	Modulelevel III Analog P.C. Board Assembly	2 pages	rev R	2008.03.24
09-9339-001			rev D	2008.04.24
009-9327-001		2 pages	rev A	2008.08.08
094-5062	HART Wiring Board	1 page		2008.08.01