



Institut scientifique
de service public

Métrieologie environnementale
Recherche - Analyses
Essais - Expertises

Siège social

et site de Liège :

Rue du Chéra, 200
B-4000 Liège
Tél : +32(0)4.229.83.11
Fax : +32(0)4.252.46.65

Site de Colfontaine :


Zoning A. Schweitzer,
rue de la Platinerie
B-7340 Colfontaine
Tél : +32(0)65.61.08.11
Fax : +32(0)65.61.08.08

e-mail :

direction@issep.be

site web :

http://www.issep.be



- (1) **EC TYPE EXAMINATION CERTIFICATE**
- (2) **Equipment or protective system intended for use
in potentially explosive atmospheres
Directive 94/9/EC**
- (3) EC type examination certificate number: **ISSeP10ATEX046X**
- (4) Equipment : Flow transmitter
Model TA2
- (5) Applicant – Manufacturer :
Magnetrol International N.V.
- (6) Address: Heikensstraat 6
9240 Zele
- (7) This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- (8) ISSeP, notified body n° 492 in accordance with article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in annex II to the Directive.
- The examination and test results are recorded in confidential report no 10073
- (9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN 60079-0:2009 (IEC 60079-0:2007) EN 60079-1:2007 (IEC 60079-1:2007)
- (10) If the symbol "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate
- (11) This EC TYPE EXAMINATION CERTIFICATE relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of this Directive may apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- (12) The marking of the equipment or protective system shall include the following indications:
 II 2 G Ex d IIC T6 Gb

Colfontaine, the 30.09.2010

INSTITUT SCIENTIFIQUE DE SERVICE PUBLIC
Zoning A. Schweitzer - B7340 Colfontaine (Wasmès)
Tél: ++ 32 65 610811 – Fax: ++ 32 65 610808
e-mail : colfontaine@issep.be

M. Lambert
Manager

This certificate may only be reproduced in its entirety and without any change, schedule included



(13)

SCHEDULE

(14)

EC TYPE EXAMINATION CERTIFICATE No ISSeP10ATEX046X

(15)

Description of the equipment:

Thermatel TA2 mass flow transmitter.

The flameproof housing of this apparatus, available in two versions, is made of aluminium alloy or stainless steel.

The integral version consists of a enclosure with two compartments on which two covers are screwed. One of the covers is provided with a window.

The measuring probe is screwed on the central part of this housing by means of a threaded adapter and an extension tube (optional)

The remote version consists of an enclosure with one compartment of which the probe is screwed at the bottom. This housing contains only the remote board with terminal blocks.

Each housing shall be equipped with certified Ex d IIC cable entries

The unused threaded holes shall be plugged with certified threaded plugs

This apparatus bears the type designation:

T A 2 - A * * 0 - * * *

Signal output _____

Display _____

Calibration _____

Housing _____

Enclosure type _____

Eventual prescriptions

Ambient temperature range: -40°C up to +55°C

Electrical characteristics

100 to 264 VAC 50 or 60 Hz

11.6 to 30 V DC

Routine test

The manufacturer shall make the routine verifications and tests necessary to ensure that the electrical apparatus produced complies with the specification submitted to the testing station together with the prototype.

The housings are exempted from the overpressure routine test. However the extension tube shall be submitted to an overpressure test of 2000 kPa (20 bar) maintained during at least 10 seconds.

(16)

Report no 10073 of 29.09.2010 composed in total of 23 pages.

The e-mail from the manufacturer dated 7 September 2010

The installation and operating manual Ref. 54-631 (72 pages)

The drawings

99-7198 of 1.10.2001 Rev E of June 2010 - signed on 7 September 2010 (4 sheets)

(17)

Special conditions for safe use: symbol X

- The temperature class T6 of this apparatus may be affected if the temperature of the measured fluid or process exceeds 55°C.

- The values of the flameproof joints are detailed in the drawings listed reference 99-7198

(18)

Essential Health and Safety Requirements: covered by the standards listed at point 9 and by the descriptive documents of the manufacturer

This certificate may only be reproduced in its entirety and without any change, schedule included